

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/31/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155342		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 1415 COUNTRY CLUB ROAD B. WING _____		(X3) DATE SURVEY COMPLETED R 07/17/2012	
NAME OF PROVIDER OR SUPPLIER MOUNT VERNON NURSING AND REHABILITATION CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 1415 COUNTRY CLUB RD MOUNT VERNON, IN 47620			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 05/09/12 and a Quality Assurance Walk-thru Survey were conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 07/17/12</p> <p>Facility Number: 000234 Provider Number: 155342 AIM Number: 100273490</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this PSR survey, Mount Vernon Nursing and Rehabilitation Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility with a partial basement was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection on both levels including the corridors and spaces open to the corridors, and battery operated smoke detectors in all resident rooms. The facility has a capacity of 76 and had a census of 63 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/31/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155342		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 1415 COUNTRY CLUB ROAD B. WING _____		(X3) DATE SURVEY COMPLETED R 07/17/2012	
NAME OF PROVIDER OR SUPPLIER MOUNT VERNON NURSING AND REHABILITATION CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 1415 COUNTRY CLUB RD MOUNT VERNON, IN 47620			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>Continued From page 1 detector coverage.</p> <p>All areas where the residents have customary access were sprinklered. A detached house to the west of the facility used for activities storage was not provided with sprinkler coverage.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 07/23/12.</p>			{K 000}			